

Facility Report

Findings	Recommendations	Estimated Unit Cost	Actual Cost	Projected Finish Date	Actual Finish Date	Notes and Comments
Adaptive Physical Education						
Restrooms						
<i>Adaptive Physical Education Accessible Showers</i>						
Record Number: 1770						
The water control lever provided in the shower compartment designated to be accessible in the men's and women's restroom at the Adaptive P.E. Building.	Remount the water control lever provided in the shower compartment designated to be accessible in each restroom at a height no greater than 40 inches above the finished floor. The centerline of the water control lever in the shower compartment designated to be accessible in each locker room shall be within 18 inches to 24 inches from the rear edge of the seat (see CBC 1115B.6.2.4.1).	\$554.00				
Record Number: 1771						
The soap dish in the shower compartment designated to be accessible in the men's and women's restroom at the Adaptive P.E. Building is mounted at a height greater than 40 inches above the shower floor.	Relocate the soap dish mounted in the shower compartment designated to be accessible in each restroom so that it is mounted on the same wall as the water controls at a maximum height of 40 inches above the shower floor (see CBC 1115B.6.2.4.6).	\$277.00				
<i>Adaptive Physical Education Men's Restroom</i>						
Record Number: 1761						
There is signage indicating accessibility on the entry door to the restroom. The signage is centered 60 inches above the floor on the latch side of the entrance door and includes Braille and raised lettering, gender use symbol and the ISA symbol.	The restroom is designated accessible and should be made an accessible restroom for the facility. Monitor signage for continued compliance with CBC 1115B.5, ADAAG 4.1.2(7) and ADAAG 4.1.6(3)(e)) and ADAAG 4.30.	\$0.00				
Record Number: 1762						
The length of the back grab bar in the restroom is less than 36 inches.	Replace the back grab bar in the restroom with a 36-inch back grab bar complying with ADAAG 4.26 and CBC 1115B.8. Grab bars must be able to support a point load of at least 250 pounds and shall be less than the allowable shear stress of the grab bar material.	\$531.00				

Findings	Recommendations	Estimated Unit Cost	Actual Cost	Projected Finish Date	Actual Finish Date	Notes and Comments
Record Number: 1763 The side grab bar in the restroom does not extend 54 inches from the back wall.	The front end of the grab bar shall extend at least 54 inches from the back wall and the back end of the grab bar shall be mounted within 12 inches from the back wall. Grab bars must be able to support a point load of at least 250 pounds and shall be less than the allowable shear stress of the grab bar material.	\$531.00				
Record Number: 1764 The distance from the center of the toilet to the nearest side wall in the restroom is greater than 18 inches.	Relocate the toilet so that the distance from the centerline of the toilet to the nearest side wall in the restroom is exactly 18 inches (see ADAAG Figure 28).	\$1,143.00				
Adaptive Physical Education Men's Restroom at Rm 107						
Record Number: 1772 There is signage indicating accessibility on the entry door to the restroom. The signage is centered 60 inches above the floor on the latch side of the entrance door and includes Braille and raised lettering, gender use symbol and the ISA symbol.	The restroom is designated accessible and should be made an accessible restroom for the facility. Monitor signage for continued compliance with CBC 1115B.5, ADAAG 4.1.2(7) and ADAAG 4.1.6(3)(e)) and ADAAG 4.30.	\$0.00				
Record Number: 1773 The length of the back grab bar in the stall designated to be accessible of the restroom is less than 36 inches.	Replace the back grab bar in the stall designated to be accessible of the restroom with a 36-inch back grab bar complying with ADAAG 4.26 and CBC 1115B.8. Grab bars must be able to support a point load of at least 250 pounds and shall be less than the allowable shear stress of the grab bar material.	\$531.00				
Record Number: 1774 The side grab bar in the stall designated to be accessible in the restroom does not extend 54 inches from the back wall.	The front end of the grab bar shall extend at least 54 inches from the back wall and the back end of the grab bar shall be mounted within 12 inches from the back wall. Grab bars must be able to support a point load of at least 250 pounds and shall be less than the allowable shear stress of the grab bar material.	\$531.00				
Record Number: 1775 The distance from the center of the toilet to the nearest side wall in the stall designated to be accessible in the restroom is greater than 18 inches.	Relocate the toilet or stall side wall so that the distance from the centerline of the toilet to the nearest side wall in the stall designated to be accessible in the restroom is exactly 18 inches (see ADAAG Figure 28).	\$1,143.00				

Findings	Recommendations	Estimated Unit Cost	Actual Cost	Projected Finish Date	Actual Finish Date	Notes and Comments
Adaptive Physical Education Women's Restroom						
Record Number: 1755						
There is signage indicating accessibility on the entry door to the restroom. The signage is centered 60 inches above the floor on the latch side of the entrance door and includes Braille and raised lettering, gender use symbol and the ISA symbol.	The restroom is designated accessible and should be made an accessible restroom for the facility. Monitor signage for continued compliance with CBC 1115B.5, ADAAG 4.1.2(7) and ADAAG 4.1.6(3)(e)) and ADAAG 4.30.	\$0.00				
Record Number: 1756						
The door opening force for the interior entrance door to the restroom is greater than 5 pounds.	Adjust the closer on the interior entrance door to the restroom to a maximum door opening force of 5 pounds (see CBC 1133B.2.5.1 and ADAAG 4.13.11).	\$5.00				
Record Number: 1757						
The length of the back grab bar in the restroom is less than 36 inches.	Replace the back grab bar in the restroom with a 36-inch back grab bar complying with ADAAG 4.26 and CBC 1115B.8. Grab bars must be able to support a point load of at least 250 pounds and shall be less than the allowable shear stress of the grab bar material.	\$531.00				
Record Number: 1758						
The side grab bar in the restroom does not extend 54 inches from the back wall.	The front end of the grab bar shall extend at least 54 inches from the back wall and the back end of the grab bar shall be mounted within 12 inches from the back wall. Grab bars must be able to support a point load of at least 250 pounds and shall be less than the allowable shear stress of the grab bar material.	\$531.00				
Record Number: 1759						
The distance from the center of the toilet to the nearest side wall in the restroom is greater than 18 inches.	Relocate the toilet so that the distance from the centerline of the toilet to the nearest side wall in the restroom is exactly 18 inches (see ADAAG Figure 28).	\$1,143.00				
Record Number: 1760						
The controls and operating mechanisms on the feminine products dispenser in the restroom require tight grasping, pinching, or twisting of the wrist and the use of two hands to operate.	Modify or replace the feminine products dispenser in the restroom so that its controls and operating mechanisms can be operated with one hand and comply with ADAAG 4.27.4 and CBC 1117B.6.4. Make certain that the force to activate the operating controls shall be no greater than 5 pounds and that the height shall be no greater than 40 inches above the finished floor.	\$0.00				

Findings	Recommendations	Estimated Unit Cost	Actual Cost	Projected Finish Date	Actual Finish Date	Notes and Comments
Adaptive Physical Education Women's Restroom Rm107						
Record Number: 1765						
There is signage indicating accessibility on the entry door to the restroom. The signage is centered 60 inches above the floor on the latch side of the entrance door and includes Braille and raised lettering, gender use symbol and the ISA symbol.	The restroom is designated accessible and should be made an accessible restroom for the facility. Monitor signage for continued compliance with CBC 1115B.5, ADAAG 4.1.2(7) and ADAAG 4.1.6(3)(e)) and ADAAG 4.30.	\$0.00				
Record Number: 1766						
The length of the back grab bar in the stall designated to be accessible of the restroom is less than 36 inches.	Replace the back grab bar in the stall designated to be accessible of the restroom with a 36-inch back grab bar complying with ADAAG 4.26 and CBC 1115B.8. Grab bars must be able to support a point load of at least 250 pounds and shall be less than the allowable shear stress of the grab bar material.	\$531.00				
Record Number: 1767						
The side grab bar in the stall designated to be accessible in the restroom does not extend 54 inches from the back wall.	The front end of the grab bar shall extend at least 54 inches from the back wall and the back end of the grab bar shall be mounted within 12 inches from the back wall. Grab bars must be able to support a point load of at least 250 pounds and shall be less than the allowable shear stress of the grab bar material.	\$531.00				
Record Number: 1768						
The distance from the center of the toilet to the nearest side wall in the stall designated to be accessible in the restroom is greater than 18 inches.	Relocate the toilet or stall side wall so that the distance from the centerline of the toilet to the nearest side wall in the stall designated to be accessible in the restroom is exactly 18 inches (see ADAAG Figure 28).	\$1,143.00				
Record Number: 1769						
The controls and operating mechanisms on the feminine products dispenser in the restroom require tight grasping, pinching, or twisting of the wrist and the use of two hands to operate.	Modify or replace the feminine products dispenser in the restroom so that its controls and operating mechanisms can be operated with one hand and comply with ADAAG 4.27.4 and CBC 1117B.6.4. Make certain that the force to activate the operating controls shall be no greater than 5 pounds and that the height shall be no greater than 40 inches above the finished floor.	\$0.00				
Facility Totals:		\$9,656.00				