

Facility Report

Findings	Recommendations	Estimated Unit Cost	Actual Cost	Projected Finish Date	Actual Finish Date	Notes and Comments
Chapel						
Path of Travel						
Chapel						
Record Number: 1230						
There are only stairs to the primary functions provided, preventing access to individuals with mobility impairments.	Since programs, services and activities to staff, students and the public (volunteers, etc.) are provided in this location, those programs, services and activities are required to be made accessible. It is recommended that a ramp be installed or other means of vertical access.	\$9,515.00				
	Facility Totals:	\$9,515.00				