

To all Gavilan College staff and students:

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER**

Este informe contiene información muy importante sobre su agua potable.

Tradúzcalo o hable con alguien que lo entienda bien.

**Monitoring Requirements not met for Gavilan College**

Gavilan Joint Community College District (“District”) inadvertently overlooked some monitoring or testing for drinking water standards per the Lead and Copper Rule (CCR, Title 22 Sections 64670 through 64690.80)

We are required to monitor your drinking water for lead and copper every three years. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During June and September 2017, we failed to complete the monitoring or testing for lead and copper contaminants from the water delivery system..

**What should I do?**

There is nothing you need to do at this time. The table below shows that once the District conducted subsequent monitoring on January 24, 2018, the results indicated that most below the 90<sup>th</sup> percentile levels that do not exceed 0.005 mg/L for lead and 0.65 mg/L for copper. If you have health issues concerning the consumption of this water, you may wish to consult your doctor.

**What did we do to correct this situation?**

Upon notification from the State Water Resources Control Board – Division of Drinking Water (“Division”), the District agreed to resample the water delivery system within the month of June.

The District will continue to work closely with the Division to ensure that a potable and reliable source of water supply is provided to our campus at all times.

**Lead Copper Results  
1/24/2018**

Sample#	Building	Area Sampled	Copper	Lead
01	Security/Maintenance	Kitchen Sink	0.400	ND
02	Security/Maintenance	Outside Spigot	0.860	0.023
03	Cosmetology	COS 102 / Senior Lab	0.300	ND
04	Cosmetology	Cosmo Break Room Sink	0.180	ND
05	Business	BU Custodial	0.330	ND
06	Business	BU Kitchenette	0.440	ND
07	Theater	Make-Up Room Sink	0.190	ND
08	Theater	TH 127 / Shop Sink	0.480	ND

09	Multi-Purpose	MP 127 / Kitchenette	0.390	ND
10	Multi-Purpose	MP 126 / Custodial	0.270	ND
11	GECA	GECA Room 14 / N.E. Sink	0.170	ND
12	Art	AR Custodial	0.190	ND
13	Social Science	SS Kitchenette Downstairs	0.440	ND
14	Library	LI 123 / Custodial	0.270	ND
15	CDC	CD 136 Kitchenette	0.490	ND
16	HOB	HOB Faculty Room Sink	0.260	0.0061
17	Physical Science	PS 101 S.W. Sink	0.240	ND
18	Life Science	Custodial Closet Sink	0.480	0.0062
19	Math	MA 115 (MESA)	0.440	ND
20	Student Center	Health Nurse's Sink	0.230	ND
21	APE	Custodial Sink	0.260	0.0076
22	GYM	Custodial Sink	0.280	0.0062

For more information, please contact Frederick E. Harris, Vice President of Administrative Services at 408-710-9812 or [fharris@gavilan.edu](mailto:fharris@gavilan.edu).

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail.

State Water System ID#: 4300608. Date distributed: June 8, 2018.