



EDMUND G. BROWN JR.
GOVERNOR



MATTHEW RODRIGUEZ
SECRETARY FOR
ENVIRONMENTAL PROTECTION

State Water Resources Control Board

Division of Drinking Water

January 9, 2018

Mr. Jeff Gopp
Gavilan Joint Community College District
5055 Santa Teresa Blvd
Gilroy, CA 95020

WATER QUALITY MONITORING REMINDER Gavilan Joint Community College District, System No. 4300608

Dear Mr. Gopp:

Please find attached the current monitoring schedules for Gavilan Joint Community College District. The attached monitoring schedules do not cover monitoring for bacteriological constituents, lead and copper monitoring of distribution systems, 1,2,3-trichloropropane (1,2,3-TCP)*, disinfectant residuals, or treatment monitoring requirements, though they may be applicable to your water system. You will need to combine all applicable requirements to construct your overall Water Quality Monitoring Plan for 2018.

All samples must be submitted to a state certified laboratory for analysis using approved methods with results submitted to the Division via Electronic Data Transfer (EDT).

The attached monitoring schedules can also be viewed online at the Drinking Water Watch website (<https://sdwis.waterboards.ca.gov/PDWW/>). Additional access instructions are attached.

If you have any questions regarding monitoring requirements or this letter, please contact Mr. Philip Dutton at (510) 620-3654.

Sincerely,

A handwritten signature in blue ink, appearing to read "Eric Lacy".

Eric Lacy, P. E.
District Engineer, Santa Clara District
Division of Drinking Water
State Water Resources Control Board

**California recently adopted a primary drinking water standard (maximum contaminant level) for 1,2,3-TCP. Pursuant to section 64445, Chapter 15, Title 22, of California Code of Regulations, community and nontransient noncommunity water systems are required to complete four quarters of initial monitoring for 1,2,3-TCP to commence in January 2018.*

Attachments: (1) Monitoring Schedule
(2) PDWW Access HowTo_WQSchedules

cc: Santa Clara County Environmental Health Department

FELICIA MARCUS, CHAIR | EILEEN SOBECK, EXECUTIVE DIRECTOR

850 Marina Bay Parkway, Bldg. P, 2nd Floor, Richmond, CA 94804-6403 | www.waterboards.ca.gov

LAST SAMPLE DATE AND MONITORING SCHEDULE

SYSTEM NO: 4300608 NAME: GAVILAN JOINT COMMUNITY COLLEGE DISTRICT COUNTY: SANTA CLARA
 SOURCE NO: 001 NAME: WELL 01 CLASS: NTGP STATUS: Active

PSCODE	GROUP/CONSTITUENT IDENTIFICATION	LAST RESULT	UNITS	MCL	DLR	LAST SAMPLE	COUNT	FREQ MON THS	MOD	NEXT SAMPLE DUE	NOTES
4300608 - 001	GAVILAN JOINT COMMUNITY COLLEGE DISTRICT	001	WELL 01								
	IO INORGANIC										
01105	ALUMINUM	<	.0000 UG/L	1000	50	2015/07/29	7	36		2018/07	
01097	ANTIMONY	<	.0000 UG/L	6	6	2015/07/29	6	36		2018/07	
01002	ARSENIC	<	.0000 UG/L	10	2	2015/07/29	7	36		2018/07	
01007	BARIUM	<	.0000 UG/L	1000	100	2015/07/29	7	36		2018/07	
01012	BERYLLIUM	<	.0000 UG/L	4	1	2015/07/29	6	36		2018/07	
01027	CADMIUM	<	.0000 UG/L	5	1	2015/07/29	7	36		2018/07	
01034	CHROMIUM (TOTAL)	<	.0000 UG/L	50	10	2015/07/29	7	36		2018/07	
01291	CYANIDE	<	.0000 UG/L	150	100	2015/07/29	4	36		2018/07	
00951	FLUORIDE (F) (NATURAL-SOURCE)		.1100 MG/L	2	.1	2015/07/29	7	36		2018/07	
71900	MERCURY	<	.0000 UG/L	2	1	2015/07/29	7	36		2018/07	
01067	NICKEL	<	.0000 UG/L	100	10	2015/07/29	6	36		2018/07	
A-031	PERCHLORATE	<	.0000 UG/L	6	4	2015/07/29	5	36		2018/07	
01147	SELENIUM	<	.0000 UG/L	50	5	2015/07/29	7	36		2018/07	
01059	THALLIUM	<	.0000 UG/L	2	1	2015/07/29	6	36		2018/07	
	NI NITRATE/NITRITE										
00618	NITRATE (AS N)		8.1 mg/L	10	.4	2017/11/07	31	3	M	2018/02	
00620	NITRITE (AS N)	<	ND mg/L	1	.4	2016/05/17	10	36		2019/05	
	RA RADIOLOGICAL										
01501	GROSS ALPHA		0.535 PCI/L	15	3	2016/09/09	6	108		2025/09	
	S1 REGULATED VOC										
34506	1,1,1-TRICHLOROETHANE	<	ND UG/L	200	.5	2017/11/29	6	72		2023/11	
34516	1,1,2,2-TETRACHLOROETHANE	<	ND UG/L	1	.5	2017/11/29	6	72		2023/11	
34511	1,1,2-TRICHLOROETHANE	<	ND UG/L	5	.5	2017/11/29	6	72		2023/11	
34496	1,1-DICHLOROETHANE	<	ND UG/L	5	.5	2017/11/29	6	72		2023/11	
34501	1,1-DICHLOROETHYLENE	<	ND UG/L	6	.5	2017/11/29	6	72		2023/11	

LAST SAMPLE DATE AND MONITORING SCHEDULE

SYSTEM NO:	NAME:	COUNTY:								
4300608	GAVILAN JOINT COMMUNITY COLLEGE DISTRICT	SANTA CLARA								
SOURCE NO:	NAME:	CLASS:	STATUS: Active							
	WELL 01	NTGP								
4300608 - S1 001	34551 1,2,4-TRICHLOROBENZENE	<	ND UG/L	5	.5	2017/11/29	5	72	2023/11	
	34536 1,2-DICHLOROBENZENE	<	ND UG/L	600	.5	2017/11/29	6	72	2023/11	
	34531 1,2-DICHLOROETHANE	<	ND UG/L	.5	.5	2017/11/29	6	72	2023/11	
	34541 1,2-DICHLOROPROPANE	<	ND UG/L	5	.5	2017/11/29	7	72	2023/11	
	34561 1,3-DICHLOROPROPENE (TOTAL)	<	ND UG/L	.5	.5	2017/11/29	5	72	2023/11	
	34571 1,4-DICHLOROBENZENE	<	ND UG/L	5	.5	2017/11/29	6	72	2023/11	
	34030 BENZENE	<	ND UG/L	1	.5	2017/11/29	6	72	2023/11	
	32102 CARBON TETRACHLORIDE	<	ND UG/L	.5	.5	2017/11/29	6	72	2023/11	
	77093 CIS-1,2-DICHLOROETHYLENE	<	ND UG/L	6	.5	2017/11/29	5	72	2023/11	
	34423 DICHLOROMETHANE	<	ND UG/L	5	.5	2017/11/29	6	72	2023/11	
	34371 ETHYLBENZENE	<	ND UG/L	300	.5	2017/11/29	6	72	2023/11	
	46491 METHYL-TERT-BUTYL-ETHER (MTBE)	<	ND UG/L	13	3	2017/11/29	9	72	2023/11	
	34301 MONOCHLOROBENZENE	<	ND UG/L	70	.5	2017/11/29	6	72	2023/11	
	77128 STYRENE	<	ND UG/L	100	.5	2017/11/29	5	72	2023/11	
	34475 TETRACHLOROETHYLENE	<	ND UG/L	5	.5	2017/11/29	6	72	2023/11	
	34010 TOLUENE	<	ND UG/L	150	.5	2017/11/29	6	72	2023/11	
	34546 TRANS-1,2-DICHLOROETHYLENE	<	ND UG/L	10	.5	2017/11/29	6	72	2023/11	
	39180 TRICHLOROETHYLENE	<	ND UG/L	5	.5	2017/11/29	6	72	2023/11	
	34488 TRICHLOROFLUOROMETHANE	<	ND UG/L	150	5	2017/11/29	6	72	2023/11	
	81611 TRICHLOROTRIFLUOROETHANE (FREON 113)	<	ND UG/L	1200	10	2017/11/29	5	72	2023/11	
	39175 VINYL CHLORIDE	<	ND UG/L	.5	.5	2017/11/29	6	72	2023/11	
	81551 XYLENES (TOTAL)	<	ND UG/L	1750	0.5	2017/11/29	6	72	2023/11	
S2 REGULATED SOC										
	39730 2,4-D	<	ND UG/L	70	10	2017/11/29	2	108	2026/11	
	39033 ATRAZINE	<	ND UG/L	1	.5	2017/11/29	3	108	2026/11	
	39055 SIMAZINE	<	ND UG/L	4	1	2017/11/29	3	108	2026/11	

LAST SAMPLE DATE AND MONITORING SCHEDULE

SYSTEM NO: 4300608 NAME: GAVILAN JOINT COMMUNITY COLLEGE DISTRICT COUNTY: SANTA CLARA
 SOURCE NO: 002 NAME: WELL 02 CLASS: NTGS STATUS: Active

PSCODE	GROUP/CONSTITUENT IDENTIFICATION	LAST RESULT	UNITS	MCL	DLR	LAST SAMPLE	COUNT	FREQ MON THS	MOD	NEXT SAMPLE DUE	NOTES
4300608 - 002	GAVILAN JOINT COMMUNITY COLLEGE DISTRICT	002	WELL 02								
IO INORGANIC											
01105	ALUMINUM	ND	UG/L	1000	50	2015/01/14	1	36		2018/01	DUE NOW
01097	ANTIMONY	ND	UG/L	6	6	2015/01/14	1	36		2018/01	DUE NOW
01002	ARSENIC	ND	UG/L	10	2	2015/01/14	1	36		2018/01	DUE NOW
01007	BARIUM	ND	UG/L	1000	100	2015/01/14	1	36		2018/01	DUE NOW
01012	BERYLLIUM	ND	UG/L	4	1	2015/01/14	1	36		2018/01	DUE NOW
01027	CADMIUM	ND	UG/L	5	1	2015/01/14	1	36		2018/01	DUE NOW
01034	CHROMIUM (TOTAL)	ND	UG/L	50	10	2015/01/14	1	36		2018/01	DUE NOW
01291	CYANIDE	<	ND UG/L	150	100	2015/01/14	1	36		2018/01	DUE NOW
00951	FLUORIDE (F) (NATURAL-SOURCE)	0.10	MG/L	2	.1	2015/01/14	1	36		2018/01	DUE NOW
71900	MERCURY	ND	UG/L	2	1	2015/01/14	1	36		2018/01	DUE NOW
01067	NICKEL	11	UG/L	100	10	2015/01/14	1	36		2018/01	DUE NOW
A-031	PERCHLORATE	<	ND UG/L	6	4	2017/11/29	2	36		2020/11	
01147	SELENIUM	ND	UG/L	50	5	2015/01/14	1	36		2018/01	DUE NOW
01059	THALLIUM	ND	UG/L	2	1	2015/01/14	1	36		2018/01	DUE NOW
NI NITRATE/NITRITE											
00618	NITRATE (AS N)	4.5 mg/L		10	.4	2017/11/07	4	3	M	2018/02	
00620	NITRITE (AS N)	ND	UG/L	1000	400	2015/01/14	1	36		2018/01	DUE NOW
RA RADIOLOGICAL											
01501	GROSS ALPHA	<	ND PCI/L	15	3	2017/11/29	3	3		2018/02	
S1 REGULATED VOC											
34506	1,1,1-TRICHLOROETHANE	<	ND UG/L	200	.5	2016/08/16	1	36		2019/08	
34516	1,1,2,2-TETRACHLOROETHANE	<	ND UG/L	1	.5	2016/08/16	1	36		2019/08	
34511	1,1,2-TRICHLOROETHANE	<	ND UG/L	5	.5	2016/08/16	1	36		2019/08	
34496	1,1-DICHLOROETHANE	<	ND UG/L	5	.5	2016/08/16	1	36		2019/08	
34501	1,1-DICHLOROETHYLENE	<	ND UG/L	6	.5	2016/08/16	1	36		2019/08	

LAST SAMPLE DATE AND MONITORING SCHEDULE

SYSTEM NO:	NAME:	COUNTY:							
4300608	GAVILAN JOINT COMMUNITY COLLEGE DISTRICT	SANTA CLARA							
SOURCE NO:	NAME:	CLASS:							STATUS:
	WELL 02	NTGS							Active
4300608 - S1 002	34551 1,2,4-TRICHLOROBENZENE	<	ND UG/L	5	.5	2016/08/16	1	36	2019/08
	34536 1,2-DICHLOROBENZENE	<	ND UG/L	600	.5	2016/08/16	1	36	2019/08
	34531 1,2-DICHLOROETHANE	<	ND UG/L	.5	.5	2016/08/16	1	36	2019/08
	34541 1,2-DICHLOROPROPANE	<	ND UG/L	5	.5	2016/08/16	1	36	2019/08
	34561 1,3-DICHLOROPROPENE (TOTAL)	<	ND UG/L	.5	.5	2016/08/16	1	36	2019/08
	34571 1,4-DICHLOROBENZENE	<	ND UG/L	5	.5	2016/08/16	1	36	2019/08
	34030 BENZENE	<	ND UG/L	1	.5	2016/08/16	1	36	2019/08
	32102 CARBON TETRACHLORIDE	<	ND UG/L	.5	.5	2016/08/16	1	36	2019/08
	77093 CIS-1,2-DICHLOROETHYLENE	<	ND UG/L	6	.5	2016/08/16	1	36	2019/08
	34423 DICHLOROMETHANE	<	ND UG/L	5	.5	2016/08/16	1	36	2019/08
	34371 ETHYLBENZENE	<	ND UG/L	300	.5	2016/08/16	1	36	2019/08
	46491 METHYL-TERT-BUTYL-ETHER (MTBE)	<	ND UG/L	13	3	2016/08/16	1	36	2019/08
	34301 MONOCHLOROBENZENE	<	ND UG/L	70	.5	2016/08/16	1	36	2019/08
	77128 STYRENE	<	ND UG/L	100	.5	2016/08/16	1	36	2019/08
	34475 TETRACHLOROETHYLENE	<	ND UG/L	5	.5	2016/08/16	1	36	2019/08
	34010 TOLUENE	<	ND UG/L	150	.5	2016/08/16	1	36	2019/08
	34546 TRANS-1,2-DICHLOROETHYLENE	<	ND UG/L	10	.5	2016/08/16	1	36	2019/08
	39180 TRICHLOROETHYLENE	<	ND UG/L	5	.5	2016/08/16	1	36	2019/08
	34488 TRICHLOROFLUOROMETHANE	<	ND UG/L	150	5	2016/08/16	1	36	2019/08
	81611 TRICHLOROTRIFLUOROETHANE (FREON 113)	<	ND UG/L	1200	10	2016/08/16	1	36	2019/08
	39175 VINYL CHLORIDE	<	ND UG/L	.5	.5	2016/08/16	1	36	2019/08
	81551 XYLENES (TOTAL)	<	ND UG/L	1750	0.5	2016/08/16	1	36	2019/08
S2 REGULATED SOC									
	39730 2,4-D	<	ND UG/L	70	10	2016/08/16	1	108	2025/08
	39033 ATRAZINE	<	ND UG/L	1	.5	2016/08/16	1	108	2025/08
	39055 SIMAZINE	<	ND UG/L	4	1	2016/08/16	1	108	2025/08

LAST SAMPLE DATE AND MONITORING SCHEDULE

SYSTEM NO: 4300608

NAME: GAVILAN JOINT COMMUNITY COLLEGE DISTRICT

COUNTY: SANTA CLARA

SOURCE NO: 900

NAME: OUTSIDE TAP SOUTH SIDE OF THEATER

CLASS: OTHR

STATUS: Active

PSCODE	GROUP/CONSTITUENT IDENTIFICATION	LAST RESULT	UNITS	MCL	DLR	LAST SAMPLE	COUNT	FREQ MONTHS	MOD	NEXT SAMPLE DUE	NOTES
4300608 - 900	GAVILAN JOINT COMMUNITY COLLEGE DISTRICT	900	OUTSIDE TAP SOUTH SIDE OF THEATER								
	D BP										
	DISINFECTION BYPRODUCTS										
	A-049 HALOACETIC ACIDS (5) (HAA5)	<	ND UG/L	60	-----	2017/06/21	4	12	M	2018/06	
	82080 TOTAL TRIHALOMETHANES		4.3 UG/L	80	-----	2017/06/21	4	12	M	2018/06	